



**REDUCTION OF
RADIOLOGICAL
ACCIDENT
CONSEQUENCES**

WP:	WP2 “METHOD”
Task:	T2.1.1 “Review of release evaluation methodologies”
Speaker:	Dorel OBADA
Affiliation:	IRSN
Event:	R2CA FINAL OPEN WORKSHOP
When:	November 29-30, 2023
Where:	Fontenay-aux-Roses, France

- **Objective** : Review and harmonize methods for evaluation of the radiological consequences
 - To evaluate Radiological consequences, release source term is required
- Task 2.1.1: Review of the release evaluation methodologies
- Template to describe the source term evaluation:
 - From isotopic inventory to release outside of containment
 - For LOCA and SGTR
- 3 reactor types:
 - PWR (IRSN) & PWR (Tractebel & Bel V)
 - VVER (SSTC NRS) & VVER (ARB NPPS)
 - BWR (LEI)



Source term evaluation in LOCA scenario

- Isotopic inventory
- Elements volatility
- FP release from fuel to the containment
- Iodine chemistry and CSS operation
- Containment building leak rate
- FP release to the environment






	PWR	VVER	BWR
Code and method used	<u>IRSN</u> : VESTA code (IRSN), Monte-Carlo <u>Tractebel & Bel V</u> : Deterministic, ORIGEN-2 code	<u>SSTC NRS</u> : Deterministic, based on fuel supplier data, additional calculations with specific codes (SCALE, MCNP, etc.) <u>ARB</u> : Supplied by the fuel supplier + additional calculations with ORIGEN and SCALE codes	SCALE code
Discretization	<u>IRSN</u> : Average of 8 different fuel types (based on irradiation and core management) <u>Tractebel & Bel V</u> : Only volatile FP inventory is used in the calculation (ORIGEN-2 for LOCA)	<u>SSTC NRS</u> : Average of several different types of similar fuel assembly <u>ARB</u> : Average of 4 different types of similar fuel assembly (similar irradiation)	One BWR 10x10 fuel bundle
Burn-up considered	<u>IRSN</u> : Realistic burn-up distribution for each assembly type at end of cycle <u>Tractebel & Bel V</u> : 650 days full operation at 3135 MW _{th} (end of cycle);	<u>SSTC NRS</u> : Realistic BU distribution for each assembly type at end of cycle <u>ARB</u> : Maximum BU for each assembly type	Average burn-up
Conditions	<u>IRSN</u> : Power at end of cycle	<u>SSTC NRS</u> : Steady state at full nominal power <u>ARB</u> : Full power at end of cycle	Steady state at full nominal power
% of ruptured fuel rods	<u>IRSN</u> : 33% <u>Tractebel & Bel V</u> : 100%	<u>SSTC NRS</u> : 100% <u>ARB</u> : 100%	55,5%



Fission products release into the containment



REDUCTION OF RADIOLOGICAL CONSEQUENCES
OF DESIGN BASIS & DESIGN EXTENSION ACCIDENTS




Contributing hypotheses:

- Fuel release rate
- Fuel rods failure rate





Fission products release into the containment



Contributing hypotheses:



- Fuel release rate
- Partitioning between the liquid/gas phase of the containment
- Fuel rods failure rate






Iodine chemistry in the containment and CSS operation

- Instantaneous modelling: all iodine species are considered initially at the break and do not evolve
- Time-dependent modelling: iodine species undergo chemical reactions and evolve over time
- Major differences regarding the operation and the efficiency of the containment spray system





Containment building leak rate




- Most hypotheses are conservative and assume a 100% release to the environment, bypassing the auxiliary buildings;
- Containment maximum leak rates are broadly similar between project partners, but the leak rate evolution is different;
- For IRSN double containment units, 1.35% vol/day and 4.35% vol/day leaks are collected in the annular space between the two containments;



Fission products release to the environment




REDUCTION OF RADIOLOGICAL CONSEQUENCES
OF DESIGN BASIS & DESIGN EXTENSION ACCIDENTS



Most impactful hypothesis for the iodine species release:

- Containment Spray System operation => molecular iodine and aerosol settling





Primary coolant activity:


- Evaluated differently for different reactor types
- Different list of fission products considered by every partner

Major differences regarding iodine speciation at the break:

- Molecular and particulate iodine
- Molecular, particulate and organic iodine
- No speciation at all (no discrimination between iodine species)

Iodine distribution in the SG:

- 1st approach – partitioning coefficients between liquid and gas phases of the SG (realistic or conservative)
- 2nd approach – phenomenological distribution (flashing, atomisation, SG dry-out)



Most impactful hypotheses for the iodine species release:

- Iodine distribution between liquid/steam in the SG (i.e. 100% to steam or not)
- Liquid releases to the environment

Secondary loop retention: only considered by Tractebel & Bel V in the evaluation of SGTR source term

Thank you!



This project has received funding from the Euratom research and training programme 2014-2018 under grant agreement No 847656.

